KDHE Reference No: Owner ID: ______ Facility ID: _____ 04/03 UST009 **UST Repair Notification** (Petroleum Products and Hazardous Substances) Submit to: Kansas Department of Health and Environment KDHE USE ONLY: **Bureau of Environmental Remediation** State of Kansas - Division of Environment **Storage Tank Section** APPROVED 1000 SW Jackson, Suite 410 When constructed to conform with Art. 44 Topeka KS 66612-1367 Phone: 785 296-8061 Fax: 785 296-6190 If any work involves upgrading or modifying the system, use the **UST Upgrade/Modification Application.** Use THIS form **only** if work replaces parts **in kind**, or if a cathodic protection system is being repaired (adding/replacing anodes, re-laying cable, replacing rectifier with same.) Please Print Clearly or Type I. Facility Information A. Facility Name: B. Facility Address: (city) II. Tank Owner Information A. Owner Name: B. Owner Address: _______(street) (city) (state) Phone: (____) ___ -C. Contact Person: **III.** Contractor Information A. Contractor Name: License No. & Exp. Date.: B. Contractor Address: _________(street) (state) (zip) (city) (state) (zip _Phone: (____) ___-C. Contact Person: IV. KDHE Tank or Line Nos. to be repaired:

A. Describe the repairs to be done. Attach manufacturer's repair instructions, if applicable: ______

- B. Describe reason for repairs:
- C. Are tanks to be taken out of service because of this proposed repair? Yes No
- D. Have tank or line failures lead to this proposed repair? Yes ____ No ____
- If yes, to whom was the leak reported? E. If failures have occurred, please briefly describe the incident:
- F. Is this facility in the State Trust Fund for environmental cleanup? Yes No

V. System Test:

- A. A tightness test must be performed within thirty (30) days if repairs were done to portions of the UST system that routinely contain fuel. Only that portion of the system repaired must be tested. A printout from an automated monthly monitoring device may be substituted for a tightness test. Test method used:
- B. If the cathodic protection system has been repaired, a system test must be performed within six months of repair. Impressed current cathodic protection systems must also be inspected within sixty (60) days of repair.

VI. Applicant's Certification:

I certify that the information above is true to the best of my knowledge and that all equipment will be repaired in compliance with the manufacturers' repair instructions if applicable. The repair will be performed in compliance with all federal, state, and local regulations.

KDHE Licensed Installer's Signature IO# (Date)